



Defence Infrastructure Organisation

DIO Ref. DE/C/SUT/43/10/1/5513

Ministry of Defence
Safeguarding
Kingston Road
Sutton Coldfield
West Midlands B75 7RL
United Kingdom

Telephone [MOD]: +44 (0)121 311 2443
Facsimile [MOD]: +44 (0)121 311 2218
E-mail: dioopsnorth-lms7b@mod.uk

Secretary of State for Energy & Climate Change
c/o Robert Pridham
National Infrastructure Consent Team
Department for Energy & Climate Change
Area A, 3rd Floor,
3 Whitehall Place
London. SW1A 2AW

21 May 2013

Dear Mr Pridham

Llandinam Windfarm 2013 Supplementary Environmental Information

The Ministry of Defence (MoD) has received notification from CeltPower Limited that the number of turbines proposed within the Llandinam wind farm has reduced from 42 turbines to 34.

The MoD submitted a response to DECC dated 3rd February 2012 raising no objection to the proposal and requesting the inclusion of a condition on any forthcoming consent that suitable aviation lighting is installed, for air safety purposes.

The MoD has reviewed this response in light of the amendments to the proposed wind farm and I can confirm that the MoD raises no objection to the proposal. The MoD requests that the turbines are fitted with aviation lighting of the following specification; *the perimeter turbines shall be installed with MoD accredited 25 candela omni-directional red lighting or infrared lighting with an optimised flash pattern of 60 flashes per minute of 200ms to 500ms duration at the highest practicable point. The cardinal turbines shall be fitted with combination lighting (IR lighting with a small element of embedded visible red lighting).*

I trust that the above will be taken into account during consideration of the application. Should you require any additional information, please do not hesitate to contact me.

Yours sincerely

Lucy Hodgetts
BSc (Hons) MA MRTPI
Senior Safeguarding Officer (Engagements)