

Sent: 04 March 2014 13:26

To: Pridham Robert (Energy Development)

Subject: 20140304-DIO 5268-Carnedd Wen Wind Farm-Submission of Environmental Information-U

Good Afternoon Robert,

Further to my e-mail below, can you please note that there should be 25cd or Infra Red lighting on the perimeter turbines and Combi Lighting on the cardinals.

Regards

Michael Billings

Safeguarding Assistant

Infrastructure Professional Services - Safeguarding

DIO Operations Development and Coherence